



### TENDER NOTICE: INTENTION TO AWARD A CONTRACT

(Published in terms of section 45(3)(b) of the Public Procurement Act No. 7 of 2011 on the public procurement website: [www.sppra.co.sz](http://www.sppra.co.sz))

<b>DATE OF FIRST PUBLICATION OF THIS NOTICE</b>	<b>25 October 2022</b>
TENDER No.	RFQ-NDMA2022/03
TENDER NAME	CONCRETE BRICKS AND READY MIX
APPROVAL AUTHORITY	NDMA Tender Board
PROCURING ENTITY	National Disaster Management Agency
REQUESTING ENTITY	None

In terms of section 45 of the Public Procurement Act No. 7 of 2011 (the Act), following a competitive bidding process, notice is hereby given that a contract award decision for the above cited tender has been reached by the approvals authority as follows:

NAME OF TENDERER	Kunto Investments	Premium Gulf Investments
NATIONALITY	Swati	Swati
AMOUNT AWARDED	E	E
4.5" Bricks	8.50	11.12
6" Bricks	9.50	12.32
9" Bricks	11.50	14.94
Concrete strength		
Ready Mix 6M <sup>3</sup> with Transport	24,725.00	18,810.00
Brick strength	4.4MPA	4.5MPA
Transport for Ready Mix		

It must be noted that, in terms of section 45(2) of the Act, the above contract award decision does not constitute a contract. All tenderers are hereby notified that a period of 10 working days shall be allowed for administrative reviews before a contract is entered into with the best evaluated tenderer.





### **DETAILS OF OTHER BIDDERS**

<b>S/N</b>	<b>NAME OF SUPPLIER</b>	<b>PRELIMINARY EVALUATION ANALYSIS</b>
1	Concrete Legacy	Met the specification for brick strength of 4MPA. Their brick test is 4.2MPA. Prices too high
3	Reliable Construction	Concrete Brick strength certificate not submitted
4	MBK Hardware	Failed to meet the minimum specification on the brick strength as their brick strength is 3.7MPA.
6	Emakholo	Failed Preliminary Examination. Reference submitted was for supply of cement and thus considered not relevant to requirement
7	Top EMS Construction	Failed Preliminary Examination. Reference submitted was for supply of cement and thus considered not relevant to requirement

**SECRETARY TO THE TENDER BOARD**

